

## ADDENDUM #3

**Date:** December 3, 2018  
**Project No.** 17205  
**Project Name:** Access Drive and Trailhead (Pigeon Forge, Tennessee)

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the Contract Documents for the above-referenced project.

Failure to acknowledge this addendum in the Bid Form may result in the Bid being deemed non-responsive.

Where any original item is amended, voided, or superseded hereby, the provision of such item not so specifically amended, voided, or superseded shall remain in effect.

---

### QUESTIONS:

1. Additional information was requested for the concrete base and flush in-ground pull box shown on detail 6, C4.00.

### CLARIFICATIONS:

1. The City of Pigeon Forge will provide the pre-formed concrete bases shown on the detail. The wiring is internal to the pole lights and will not require the flush in-ground mounted pull box for installation.
2. **REMINDER: Bid Date Extension:** Due to late questions submitted, the bid opening date has been extended to 2pm December 13, 2018.

NOTE: Receipt of this Addendum must be acknowledged on the Bid Form.

END OF ADDENDUM