

NOTICE OF BID

The City of Pigeon Forge is receiving equipment bids for a 15 ton package air-conditioning unit for the Public Works Water Treatment Plant.

Specifications may be obtained from the Public Works Department in City Hall between the hours of 8:00 and 4:30 p.m., Monday thru Friday.

All bids must be in sealed envelope with bidders name and address on outside and marked "Bid on Air Conditioning Unit."

Bids will be received until 2:00 p.m., September 6, 2017, at which time they will be opened and read aloud.

The City reserves the right to reject any or all bids or to accept the bid most favorable to the City.

This 18th day of August, 2017.

Department of Public Works
Pigeon Forge, Tennessee

SPECIFICATIONS

One 15 ton package air conditioning unit with thermostat or controller.

Unit will replace a Trane Voyager Model No. TCH180B400GA.

Unit will be a horizontal configuration with side supply and return.

Unit shall have two (2) or more independent refrigerant circuits.

No factory heat.

460 V, 3 phase.

Supplier will provide initial factory authorized start-up of unit after installation is complete.

Existing unit can be viewed at Water Treatment Plant, 2432 Library Drive, Pigeon Forge, TN. Viewing of existing unit will be for one week, Monday thru Friday, 8 am – 2 pm, 865-453-1275

All bidders to provide spec sheet with bid.

Bid must include freight/shipping to job site, 2432 Library Drive, Pigeon Forge, TN 37863.

One year standard factory warranty or longer.

BID SHEET

Bidder: _____

Address: _____

Contact Person: _____

Email: _____ Phone: _____

Bid: _____

Alt. Bid #1: Cost for installation of unit: _____

Alt. Bid #2: Cost to purchase an extended warranty: _____

Delivery Time: _____

Signature

Date