



**PIGEON FORGE**  
**T.E.N.N.E.S.S.E.E**

DEPARTMENT OF PUBLIC WORKS

MARK MILLER  
DIRECTOR

### **NOTICE OF BID**

The City of Pigeon Forge Department of Public Works is receiving sealed bids on Sodium Hypochlorite Storage Tank with Stand.

Specifications may be obtained from the Public Works Department in City Hall between the hours of 8:00 am and 4:30 pm, Monday through Friday.

All bids must be in sealed envelope with bidders name and address on outside and marked "Bid on Sodium hypochlorite Storage Tank with Stand."

Bids will be received until 2:15 pm, March 20, 2018, at which time they will be opened and read aloud.

The City reserves the right to reject any or all bids or to accept the bid most favorable to the City.

This 27th day of February, 2018.

Department of Public Works  
Pigeon Forge, Tennessee

BID SHEET

Firm Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

\_\_\_\_\_

Contact Name: \_\_\_\_\_

Phone: \_\_\_\_\_

Email: \_\_\_\_\_

FAX: \_\_\_\_\_

Approximate Delivery Time: \_\_\_\_\_

## **Sodium Hypochlorite Storage**

### **Tanks w/ Stand**

### **Bid Specifications**

Qty. = 6

1600 gallon cone bottom tanks with stand.

1.9SG HDLPE.

Maximum height of tanks with stands to be 98".

Maximum width of tanks or stands to be 98".

Each tank to have 18" PE Threaded manway cover w/15" access.

Each tank to have 2" bulkhead fitting with viton seals in top center.

Each tank outlet @ bottom to be 2" PVC flange/HST BLT-viton.

Tank/stand specs and drawings/diagrams to be submitted with bid.

Pricing for shipping to be included.